

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7300-1521:137

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089
Contact: Ferd Orpano (847) 941-6176 FAX (866) 699-0238

DESIGN: Model SIGA-AB4G-LG smoke detector base with integral audible signal. Model AB4G-SB backbox for use with detector base. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 16-33 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a smoke detector base for use with listee's separately listed SIGA series smoke detector heads and fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7300-1591:222

09-14-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 14, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**